

**ARMY PUBLIC SCHOOL JODHPUR**


**MINUTES OF POINTS DISCUSSED DURING THE PRE-BID MEETING - PROCUREMENT AND INSTALLATION OF LIGHTS AND OTHER ITEMS FOR SPORTS GROUND**

1. Pre-Bid Meeting in respect of tender invited by Army Public School Jodhpur for **Procurement and Installation of Lights and Other Items for Sports Ground** was held on 20 Apr 2024. The vendors were briefed in detailed about the requirement and shown the site.


2. The following points were discussed and decision/amendments given thereon :-

S. No	Points Discussed	Decision/Amendments Given by the Board	Remarks
(a)	Make of the Pole need to be mentioned	Iron Poles will be provided as discussed	
(b)	Diameter to be provided by Vendor along with gauge	Pole diameter of size 14 cm	
(d)	Staircase on poles to be provided for maint of lights	Staircase to be provided by the vendor for each pole.	
(d)	Brand of the Pole also need to be mentioned	Brand of JK/Jindal/Equivalent Brand to be given.	
(e)	Brand of Lights to be given	Philips/Bajaj/Crompton/Havells	
(f)	Earthing to be given	Shown on the ground by the adm supervisor and it was decided that earthing will be given for each pole	
(g)	Thickness of Cable alongwith make of cable is to be provided	Pole to Pillar Aluminum cable of 50 sq mm is required, rate of running meter also need to be given by the vendor in the tender document. RR Cabels/ Havells/ Equivalent Brand	
(h)	Wiring from existing MCB Box also need to be verified	MCB to Lights copper cable of 4 to 6 sq mm is required, rate of running meter also need to be given by the vendor in the tender document. RR Cabels/ Havells/ Equivalent Brand	


(a) Presiding Officer

  
(Maj Vikas Yadav)  
113 Med Regt (SO to Chairman)


(b) Member (i)

  
(Dr (Mrs) Tabassum Khan)  
Principal, APS Jodhpur

(ii)

  
(Dr (Mrs) Ifam Khan)  
Adm Offr, APS Jodhpur

(iii)

  
(Mr Raj Saraswat)  
PGT (PE), APS Jodhpur